



Thermos Bottle Buildings

Roy Swain, P.E.









EXISTING HVAC CONTROLS


ALWAYS HEATING & COOLING AT SAME TIME



REHEAT COIL AND COOLING COIL OPERATION



DEAD BAND CONTROLS




REHEAT COIL AND COOLING COIL OPERATION

WALL TYPE /

Prepared by: John Paoluccio Consulting Engineers

P-189



List of Construction Components

	R
1. 0.5" Gypsum or Plaster Board, 50 lb./cu. ft.	<u>0.45</u>
2. R-11 Mineral Fiber Insulation	<u>11.00</u>
3. 26 ga. Steel Sheet Metal Panel	<u>0</u>
4.	_____
5.	_____
6.	_____
7.	_____
8.	_____

Inside Surface Air Film	<u>0.68</u>	<u>0.68</u>
	cooling	heating

Outside Surface Air Film	<u>0.25</u>	<u>0.17</u>
	cooling	heating

Total Resistance R_t	<u>12.38</u>	<u>12.30</u>
	cooling	heating

U-Value ($1/R_t$)	<u>0.0808</u>	<u>0.0813</u>
	cooling	heating

U-Value Adjusted for Framing	<u>0.11</u>	<u>0.11</u>
	summer	winter

Sketch of Construction Assembly

WEIGHT: 7 lb/ft²

Check one:


Wall

Roof

Floor

FRAMING:

2" x 4" @ 16" o.c.




PROJECT SUMMARY
 CONDITIONED WAREHOUSE & PACKAGING ROOM

PAOLUCCIO CONSULTING ENGINEERS	HERSHEY FOODS CORPORATION	FIGURE 1
	ENERGY CONSERVATION PROJECT	

Heating/Cooling Balance Point ~~Graph~~ Graph

Assumes Occupied Hours: 23 & 1/2 hr



Lyme Inn































Digital Sound Level Meter

UNDER

50

FAST

100

41.9 dB

Range 30dB ~ 130dB

POWER

MAX

LEVEL

A/C

FAST SLOW



TELAIRE

CO₂ 668 ppm
VELOCITY RATE
36.8 cm/p

enter

power

mode





“Thermos Bottle” Building Design Heat Loss

-10°F outside, 70°F Inside

<u>Building Element</u>	<u>Heat Loss</u>
R-60 Roof	10%
R-40 Walls (and Doors)	25%
R-20 Basement/Foundation Walls	25%
R-10 Basement Floor	5%
R-5 Windows (10% of floor area)	35%
Total	100%
Approximate BTUH/ Sq. Ft.	5
For typical 150 Sq. Ft. Room:	750 BTUH (Hair Dryer on “Low”)

Note: Excludes infiltration/ventilation

“Thermos Bottle” Building Design Internal Heat Gain Per Person 0-150 Sq. Ft./Person

Heat Source	Btuh/Person
Body Heat (Sensible)	250
Lights*	400
Plug Loads**	400
Total	1050

* $0.75 \text{ Watts/Sq. Ft.} \times 150 \text{ Sq. Ft.} \times 3.412 \text{ Btuh/Watt} (=384)$

** Wilkins and Hosni, Plug Load Design Factors (ASHRAE Journal, May 2011, P. 30.

Ventilation Air for One Person

$$15 \text{ cfm/} \times 1.08 = 16 \text{ Btuh}$$

$$\frac{300 \text{ Btuh net heat gain}}{16 \text{ Btuh/}^\circ\text{F}} = \sim 20^\circ\text{F}$$

Therefore at -10°F outside air the 15 cfm of ventilation air needs to be at 55°F (!) to balance out the net heat gain assuming 75°F inside.

And assuming zero solar heat gain through the windows.

Economizer Cooling

Per person, ignoring heat loss, at 150 Sq. Ft. / Person


$$Q = \text{CFM} \times 1.08 \times \Delta T$$

For 1050 Btuh/person heat gain:

- For 20°F $\Delta T = 50$ CFM
 - Or 1/3 CFM per Sq. Ft.
- For 10°F $\Delta T = 100$ CFM
 - Or 2/3 CFM per Sq. Ft.
- For 5°F $\Delta T = 200$ CFM
 - Or 1-1/3 CFM per Sq. Ft.

PSYCHROMETRIC CHART

© 1969 THE TRANE COMPANY, LA CROSSE, WISCONSIN
Barometric Pressure 29.921 inches of Mercury



















2A* III

EXIT



EXIT

FLOOR 1
LEVEL 1



















RECO
USA

HEATING WATER SUPPLY
↓

HEATING WATER RETURN
↑

ER 140°





Hubbell

A DANGER

WARNING

Hubbell

0113

110V 15A

1500VA

UL 1449

UL 1451

UL 1452

UL 1453

UL 1454

UL 1455

UL 1456

UL 1457

UL 1458

UL 1459

UL 1460

UL 1461

UL 1462

UL 1463

UL 1464

UL 1465

UL 1466

UL 1467

UL 1468

UL 1469

UL 1470

UL 1471

UL 1472

UL 1473

UL 1474

UL 1475

UL 1476

UL 1477

UL 1478

UL 1479

UL 1480

UL 1481

UL 1482

UL 1483

UL 1484

UL 1485

UL 1486

UL 1487

UL 1488

UL 1489

UL 1490

UL 1491

UL 1492

UL 1493

UL 1494

UL 1495

UL 1496

UL 1497


UL 1498


UL 1499

UL 1500



Legionella Temperatures









Moving Towards Simplicity

